

# Certificate of Conformity

By the product certificate number

No. 2622/0478-D-E2-CER

Issued to:

License holder:

**Victron Energy B.V.**  
De Paal 35, JG Almere 1351 JG Almere-Haven - The Netherlands

Trademark:



Contract number:

802190

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Models	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Technical Data			
Rated AC Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V	
Rated Frequency		50 Hz	
Firmware version	2621502	2627502	2619502
Number of phases		Single Phase (L/N/PE)	
Isolation transformer		Yes	

Is in compliance with the standard:

- **G99/NI Issue 1 (April 2019):** "Requirements for the connection of generation equipment in parallel with public distribution networks in Northern Ireland on or after 27 April 2019"
- **G99 Issue 1 – Amendment 9 (October 2022):** "Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019".

The above-mentioned generating unit is certified according to the SGS internal process No. 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes certificate no. 2622/0478-D-E1-CER.

This certificate is first issued on 26<sup>th</sup> March 2024.

This certificate is valid until the 08<sup>th</sup> June 2028.

Madrid, 26<sup>th</sup> March 2024.

Daniel Arranz Muñiz  
Certification Manager

